


8. External input and output



Connection point		Input/Output	Function	Input select	Input signal
Indoor unit	CN46	Input	Operation/Stop Forced stop	Dry contact	Edge
	CN47	Output	Operation status	—	—
			Error status		
External input and output PCB (UTY-XCSXZ2)	CN313	Input	Indoor unit fan operation status		
	CN314		Operation/Stop	Dry contact/Apply voltage	Edge/Pulse
	CN313		Forced stop		Edge
	CN310	Output	Forced thermostat off	—	—
	CN311		Operation status		
	CN312		Error status		
			Indoor unit fan operation status		

NOTE: For details of the switching function, refer to "[Setting of external input and output](#)" on page 22.


8-1. External input

With using external input function, some functions on this product can be controlled from an external device.

- “Operation/Stop” mode or “Forced stop” mode can be selected with function setting of indoor unit.
- A twisted pair cable should be used. Maximum length of cable is 150 m.
- Use an external input and output cable with appropriate external dimension, depending on the number of cables to be installed.
- The wire connection should be separate from the power cable line.

■ Indoor unit

Indoor unit functions such as Operation/Stop can be done by using indoor unit connectors.



*1: The switch can be used on the following condition: DC 12 V to 24 V, 1 mA to 15 mA.

■ External input and output PCB


The indoor unit Operation/Stop can be set by using the input connector on the PCB.

• Input select

Use either one of these types of connectors according to the application. (Both types of connectors cannot be used simultaneously.)

– Dry contact


In case of internal power supply, set the slide switch of SW301 to "NON VOL" side.



*1: The switches can be used on the following condition: DC 12 V to 24 V, 1 mA to 15 mA.

– Apply voltage

In case of external power supply, set the slide switch of SW301 to "VOL" side.




*1: The switches can be used on the following condition: DC 12 V to 24 V, 1 mA to 15 mA.

*2: Make the power supply DC 12 V to 24 V, 10 mA or more.

■ Input signal type

- **Indoor unit**


Input signal type is only "Edge".



- **External input and output PCB**

The input signal type can be selected.

Signal type (edge or pulse) can be switched by the DIP switch 2 (SW302) on the External input and output PCB.



NOTE: The input signal supports the following switch type:

- Edge: Alternate type switch
- Pulse: Momentary type switch


8-2. External output

Use an external output cable with appropriate external dimension, depending on the number of cables to be installed.

■ Indoor unit


- A twisted pair cable should be used. Maximum length of cable is 25 m.
- Output voltage: High DC 12 V ± 2 V, Low 0 V.
- Permissible current: 50 mA
- For details, refer to "[Setting of external input and output](#)" on page 22.
- **When indicator, etc. are connected directly**

Example: Function setting number 60 is set to "00"



- **When connecting with a device equipped with a power supply**

Example: Function setting number 60 is set to "00"




■ External input and output PCB

- A twisted pair cable should be used. Maximum length of cable is 25 m.
- Output voltage: High DC 12 V±2 V, Low 0 V.
- Permissible current: 50 mA
- For details, refer to "[Setting of external input and output](#)" on page 22.


- When indicator or other components are connected directly:**

Example: Rotary SW on External input and output PCB is set to "1".



- When connecting with a device equipped with a power supply:**

Example: Rotary SW on External input and output PCB is set to "1".



8-3. Setting of external input and output

- Indoor unit

Input		
Connection point	Function setting number 46	Function
CN46	00	Operation/Stop mode 1 (R.C. enabled)
	01	(Setting prohibited)
	02	Forced stop mode
	03	Operation/Stop mode 2 (R.C. disabled)

Output		
Connection point	Function setting number 60	Function
CN47	00	Operation status
	01 to 08	(Setting prohibited)
	09	Error status
	10	Indoor unit fan operation status
	11	(Setting prohibited)

- External input and output PCB

Switch setting		Input		Output		
Rotary switch	SW302	CN313	CN314	CN310	CN311	CN312
1	Edge	Operation/Stop	Not available	Operation status	Error status	Indoor unit fan status
	Pulse	Operation	Stop			
2	Edge*	Forced thermostat off	Not available	Error status	Indoor unit fan operation status	Not available
		(Setting prohibited)				
3 to 9, A		Forced thermostat off	Not available	Operation status	Indoor unit fan operation status	Not available
B		Forced thermostat off	Not available	Operation status	Indoor unit fan operation status	Not available
C		Forced thermostat off	Not available	Operation status	Error status	Not available
D		(Setting prohibited)				

NOTES:


- When the rotary switch is selected to “1”, the operation of the connector input of the indoor unit and the External input and output PCB input are the same. The operation content depends on the setting of function setting number 46.
- *: The external input other than “Operation/Stop” is available only when the SW302 is set to “Edge”.

8-4. Details of control input function

■ Operation/Stop mode 1


- In the case of "Edge" input

Function setting	External input and output PCB		External input	Input signal	Command
	Rotary switch	SW302			
46-00	—	CN46	Input of indoor unit	Off → On	Operation
			On → Off	Stop	
	1 Edge	CN313	External input and output PCB	Off → On	Operation
			On → Off	Stop	



- In the case of "Pulse" input

Function setting	External input and output PCB		External input	Input signal	Command
	Rotary switch	SW302			
46-00	1	Pulse	External input and output PCB	CN313 CN314	Pulse Operation Stop




NOTES:

- The last command has priority.
- The indoor units within the same remote controller group operates in the same mode.

■ Forced stop


- In the case of "Edge" input

Function setting	External input and output PCB		External input	Input signal	Command
	Rotary switch	SW302			
46-02	—	Input of indoor unit	CN46	Off → On	Forced stop (R.C. disabled)
				On → Off	Normal (R.C. enabled)
	1	Edge	External input and output PCB	CN313	Off → On
					Normal (R.C. enabled)



- In the case of "Pulse" input

Function setting	External input and output PCB		External input	Input signal	Command	
	Rotary switch	SW302				
46-02	1	Pulse	External input and output PCB	CN313	Pulse	Forced stop (R.C. disabled)
						Normal (R.C. enabled)




NOTES:

- When the forced stop is triggered, indoor unit stops and Operation/Stop operation by the remote controller is restricted.
- When forced stop function is used with forming a remote controller group, connect the same equipment to each indoor unit within the group.

■ Operation/Stop mode 2


- In the case of “Edge” input

Function setting	External input and output PCB		External input	Input signal	Command
	Rotary switch	SW302			
46-03	—	Input of indoor unit	CN46	Off → On	Operation (R.C. enabled)
				On → Off	Stop (R.C. disabled)
	1	Edge	External input and output PCB	CN313	Off → On
					Stop (R.C. disabled)



- In the case of “Pulse” input


Function setting	External input and output PCB		External input	Input signal	Command	
	Rotary switch	SW302				
46-03	1	Pulse	External input and output PCB	CN313	Pulse	Operation (R.C. enabled)
						Stop (R.C. disabled)



NOTE: When “Operation/Stop” mode 2 function is used with forming a remote controller group, connect the same equipment to each indoor unit within the group.

■ Forced thermostat off

External input and output PCB	External input		Input signal	Command
Rotary switch				
2, B, C	External input and output PCB	CN313	Off → On On → Off	Thermostat off Normal operation




8-5. Details of control output function

■ Operation status

Function setting	External input and output PCB	External output		Output signal	Status
		Rotary switch			
60-00	1, 2	Output of indoor unit	CN47	Off → On	Operation
				On → Off	Stop
—	1, B, C	External input and output PCB	CN310	Off → On	Operation
				On → Off	Stop


The output is low when the unit is stopped.



■ Error status

Function setting	External input and output PCB	External output		Output signal	Status
		Rotary switch			
60-09	—	Output of indoor unit	CN47	Off → On	Error
				On → Off	Normal
—	2	External input and output PCB	CN310	Off → On	Error
				On → Off	Normal
—	1, C	External input and output PCB	CN311	Off → On	Error
				On → Off	Normal


The output is on when an error is generated for the indoor unit.



■ Indoor unit fan operation status

Function setting	External input and output PCB	External output		Output signal	Status
	Rotary switch				
60-10	C	Output of indoor unit	CN47	Off → On	Fan run
—	2, B			On → Off	Fan stop
—	1	External input and output PCB	CN311	Off → On	Fan run
—	—			On → Off	Fan stop
—	—	External input and output PCB	CN312	Off → On	Fan run
—	—			On → Off	Fan stop

Output signal	Condition
On	The indoor unit fan is operating.
Off	The fan is stopped or during cold air prevention. During thermostat off when in dry mode operation.



9. Group connection


NOTE: Group control cannot be used together with Wireless LAN adapter.

Installation procedure for group control system:

A number of indoor units can be operated at the same time using a single remote controller.

NOTE: When different type of indoor units (such as wall mounted type and cassette type, cassette type and duct type, or other combinations) are connected using group control system, some functions may no longer be available.


1. Connect up to 16 indoor units in a system.



A, B, C, D, E: Remote controller cable

Wiring length limitation	$A + B + C + D + E \leq 500 \text{ m}$
--------------------------	--

Example of wiring method



Remote controller cable

Bus wire

Remote controller